

CERTIFICATE OF COMPLIANCE

Certificate Number 20171120-EX26942
Report Reference EX26942-20151231
Issue Date 2017-NOVEMBER-20

Issued to: TIANJIN UNITED STEEL PIPE CO LTD
NO.8 HENGTAI RD., DAQUIZHUANG, JINGHAI DISTRICT
TIANJIN
301606 CHINA

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE

Schedule 40 (Black or Galvanized) steel sprinkler pipe in
the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8 and 10 in
sizes


Schedule 10 (Black or Galvanized) steel sprinkler pipe in
the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8 and 10 in
sizes

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

